

## Certificate of constancy of performance,

**0832-CPR-F0576**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### CFP/E Range

*(For full product details and conditions of use refer to appendix)*

Produced by or for

### Computationics Limited (Trading as C-Tec)

Challenge Way  
Martland Mill Industrial Estate  
Wigan, Lancashire  
WN5 0LD  
United Kingdom

and produced in the manufacturing plant(s)

### Computationics Limited (Trading as C-Tec)

Challenge Way  
Martland Mill Industrial Estate  
Wigan, Lancashire  
WN5 0LD  
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 54-2: 1997 + A1: 2006 Control and indicating equipment**  
**EN 54-4: 1997 + A1: 2002 + A2: 2006 Power supply equipment**

under system 1 are applied and that

***the products fulfil all the prescribed requirements set out above.***

This certificate was first issued on 11 April 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



W Hunukumbure, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 11 April 2014  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

## Appendix to Certificate of constancy of performance 0832-CPR- F0576

CFP702E-4 Two zone conventional control and indicating equipment

Incorporating the units:

SPF0702480 Switch mode power supply unit board

SPF0724851 2 Zone main control board

Certified with the following options with requirements from EN 54-2: 1997

7.8 Output to fire alarm devices(s)

7.11 Delays to outputs

CFP704E-4 Four zone conventional control and indicating equipment

Incorporating the units:

SPF0702480 Switch mode power supply unit board

SPF0724853 4 Zone main control board

Certified with the following options with requirements from EN 54-2: 1997

7.8 Output to fire alarm devices(s)

7.11 Delays to outputs

CFP708E-4 Eight zone conventional control and indicating equipment

Incorporating the units:

SPF0702480 Switch mode power supply unit board

SPF0724855 8 Zone main control board

Certified with the following options with requirements from EN 54-2: 1997

7.8 Output to fire alarm devices(s)

7.11 Delays to outputs



W Hunukumbure, Certification Manager

On behalf of BRE Global Limited

Date of issue: 11 April 2014

Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).