

## Certificate of constancy of performance,

**0832-CPR-F1116**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **BF460A/CX/W Addressable Type A (indoor) Ceiling VAD Base with Short Circuit Isolator (Apollo Discovery)**

*(For full product details and conditions of use refer to appendix)*

Produced by or for

#### **Computationics (trading as CTEC) Ltd**

**Challenge Way  
Martland Park  
Wigan, Lancashire  
WN5 0LD  
United Kingdom**

and produced in the manufacturing plant(s)

#### **Computationics (trading as CTEC) Ltd**

**Challenge Way  
Martland Park  
Wigan, Lancashire  
WN5 0LD  
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

#### **EN 54-23: 2010 Visual alarm devices EN 54-17: 2005 Short circuit isolators**

under system 1 are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on 29 October 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



M McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 29 October 2015  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

## Appendix to Certificate of constancy of performance 0832-CPR- F1116

Notes:

1. Meets the requirements of EN 54-23 for the following:
  - Category C-3-8
  - Flash Rate 0.5Hz
  - Synchronisation
  - Operating voltage 21-28 VDC
2. Can be used as either:
  - a stand-alone device with locking white cap (BF330CTLIDW), or red cap (BF330CTLIDR), or
  - a stacked VAD base combination with detectors from the Apollo Discovery range



M McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 29 October 2015  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).