



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme Tick Mark Certificate

Certificate No. 14LHK0085 - 01

In accordance with the Tick Mark Rules and Certification System 5, as defined in ISO / IEC Guide 67, we certify that the product

C-Tec ActiV Conventional Range of Fire Detectors
is in conformity with the following standard(s)

EN54-5:2000+A1, EN54-7:2001+A1,A2

Report Number(s): 100742793LHD-001, 100742793LHD-003

Computationics Limited (Trading as C-Tec)

Challenge Way, Martland Park, Wigan, WN5 0LD, UK

is authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product

This certificate is valid until:

31 October 2018

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	Certification body: ITCL
	LSS Ref: LSS 0417
	Issued Date: 31 October 2014

Signed on behalf of Intertek, located at Leatherhead, United Kingdom

31 October 2014



010

Rajesh Sodha
Certification Officer





The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

Certificate No. 14LHK0085 - 01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No 1

The optional features of the specifications that are included in the product and test report:

Conditions of use;
Suitable for indoor applications

Brand and Type/Model	Description	Factory Code
C4403A1R	ActiV Conventional Class A1R rate of rise heat detector	CTEUK.01
C4403A2	ActiV Conventional Class A2 fixed temperature heat detector	CTEUK.01
C4403B	ActiV Conventional Class B fixed temperature heat detector	CTEUK.01
C4408	ActiV Conventional detector base	CTEUK.01
C4408D	ActiV Conventional diode detector base	CTEUK.01
C4414	ActiV Conventional multisensor fire detector Class A2 heat detection Class A2 heat detection	CTEUK.01
C4414	ActiV Conventional multisensor fire detector Low optical sensitivity with Class A2 heat enhancement	CTEUK.01
C4416	ActiV Conventional optical smoke detector Standard optical sensitivity	CTEUK.01



The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

Certificate No. 14LHK0085 - 01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No 2

Products compliant with EN54-5:2000 + A1:2002:

Variant

C4403A1R ActiV Conventional Class A1R rate of rise heat detector
C4403A2 ActiV Conventional Class A2 fixed temperature heat detector
C4403B ActiV Conventional Class B fixed temperature heat detector
C4414 ActiV Conventional multisensor fire detector
Class A2 heat detection

Products compliant with EN54-7:2000 + A1:2002 + A2:2006:

Variant

C4416 ActiV Conventional optical smoke detector
Standard optical sensitivity
C4414 ActiV Conventional multisensor fire detector
Low optical sensitivity with Class A2 heat enhancement

Bases:

Variant

C4408 ActiV Conventional detector base
C4408D ActiV Conventional diode detector base

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.