



The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

Tick Mark Certificate No. 14LHK0085-05

This is to certify that:

C-Tec ActiV Conventional Range of Fire Detectors

is in conformity with the following standard(s):

EN 54-5:2017+A1:2018, EN 54-7:2018

Report Number(s):

104992212LHD-021

Computationics Limited (Trading as C-Tec)

Challenge Way, Martland, Wigan, WN5 0LD, UK)

and is authorized to use the Intertek Tick Mark for the LSS Scheme on the
above mentioned product(s)

This certificate is valid until:

2nd September 2026

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	Certification Body: ITCL LSS Reference: LSS 0417 Issued Date: 20 th December 2022
See ANNEX No. 2	

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

Andrew Lawson



Intertek LSS Scheme

Tick Mark Certificate

14LHK0085-05

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 1

Brand and Type/Model	Description	Factory Code
C4403A1R	ActiV Conventional Class A1R rate of rise heat detector	CTECUK.01
C4403A2	ActiV Conventional Class A2 fixed temperature heat detector	CTECUK.01
C4403B	ActiV Conventional Class B fixed temperature heat detector	CTECUK.01
C4408	ActiV Conventional detector base	CTECUK.01
C4408D	ActiV Conventional diode detector base	CTECUK.01
C4414	ActiV Conventional multi-sensor fire detector Class A2 heat detection	CTECUK.01
C4414	ActiV Conventional multi-sensor fire detector Low optical sensitivity with Class A2 heat enhancement	CTECUK.01
C4416	ActiV Conventional optical smoke detector Standard optical sensitivity	CTECUK.01



Intertek LSS Scheme

Tick Mark Certificate

14LHK0085-05

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 2

Conditions of use:

Suitable for indoor applications.

Products compliant with EN 54-5:2017+A1:2018:

Variant

C4403A1R ActiV Conventional Class A1R rate of rise heat detector

C4403A2 ActiV Conventional Class A2 fixed temperature heat detector

C4403B ActiV Conventional Class B fixed temperature heat detector

C4414 ActiV Conventional multi-sensor fire detector Class A2 heat detection

Products compliant with EN 54-7:2018:

Variant

C4416 ActiV Conventional optical smoke detector Standard optical sensitivity

C4414 ActiV Conventional multi-sensor fire detector Low optical sensitivity with Class A2 heat enhancement

Bases:

Variant

C4408 ActiV Conventional detector base

C4408D ActiV Conventional diode detector base

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the