



Declaration of Performance – DOP0000011 **According to Construction Products Regulation EU N° 305/2011**

1. Unique Product identification code:

BF365SC, BF365IM

2. Type number allowing identification of the construction product as required pursuant to Article 11(4):

Sounder Loop Control module, Sounder Isolator module

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Short Circuit Isolators for use in Fire detection and fire alarm systems to
EN54-17: 2005

Input / Output Devices for use in Fire detection and fire alarm systems to
EN 54-18: 2005

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Compuionics Limited (C-TEC)
Challenge Way, Martland Park, Wigan, WN5 0LD. United Kingdom
Tel: 01942 322744. Fax: 01942 829867

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not Applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. Notified body, in the case of the declaration of performance concerning a construction product covered by a harmonized standard:

BSI Group, The Netherlands B.V. (Notified Body Number 2797)
John M. Keynesplein 9,
1066 EP Amsterdam
The Netherlands

has performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

2797-CPR-562187

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7



9(a). Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

| Harmonised Technical Specification | | EN54-17: 2005 |
|--|------------------------------|-----------------------------|
| Essential Characteristics | Performance | Clause |
| Performance under fire conditions - Reproducibility ⁽¹⁾ | Pass | 5.2 |
| Operational reliability - General requirements | Pass | 4 |
| Durability of operational reliability (temperature resistance) - Dry heat (operational) - Cold (operational) | Pass Pass | 5.4 5.5 |
| Durability of operational reliability (vibration resistance) - Shock (operational) - Impact (operational) - Vibration, sinusoidal (operational) - Vibration, sinusoidal (endurance) | Pass Pass Pass Pass | 5.9 5.10 5.11 5.12 |
| Durability of operational reliability (humidity resistance) - Damp heat, cyclic (operational) - Damp heat, steady state (operational) | Pass Pass | 5.6 5.7 |
| Durability of operational reliability (corrosion resistance) - Sulphur dioxide (SO ₂) corrosion (endurance) | Pass | 5.8 |
| Durability of operational reliability (electrical stability) - Variation in supply voltage - Electromagnetic Compatibility (EMC), Immunity tests (operational) | Pass Pass | 5.3 5.13 |
| ⁽¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices. | | |
| Note: BF365SC and BF365IM meet the requirements of EN54-17: 2005 and EN54-18: 2005 when used in conjunction with each other. When used singularly, the products will be deemed not to comply with the aforementioned Harmonized standard. | | |



9(b). Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

| Harmonised Technical Specification | | EN54-18: 2005 |
|--|------------------------------|----------------------------|
| Essential Characteristics | Performance | Clause |
| Response delay (response time) - Performance and variation in supply parameters ⁽¹⁾ | Pass | 5.2 |
| Performance under fire conditions - Functional test | Pass | 5.1.4 |
| Operational reliability - Functional test | Pass | 5.1.4 |
| Durability of operational reliability (temperature resistance) - Dry heat (operational) - Cold (operational) | Pass Pass | 5.3 5.4 |
| Durability of operational reliability (vibration resistance) - Shock (operational) - Impact (operational) - Vibration, sinusoidal (operational) - Vibration, sinusoidal (endurance) | Pass Pass Pass Pass | 5.8 5.9 5.10 5.11 |
| Durability of operational reliability (humidity resistance) - Damp heat, cyclic (operational) - Damp heat, steady state (operational) | Pass Pass | 5.5 5.6 |
| Durability of operational reliability (corrosion resistance) - Sulphur dioxide (SO ₂) corrosion (endurance) | Pass | 5.7 |
| Durability of operational reliability (electrical stability) - Performance and variation in supply parameters - Electromagnetic Compatibility (EMC) Immunity tests | Pass Pass | 5.2 5.12 |
| ⁽¹⁾ Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard. | | |
| Note: BF365SC and BF365IM meet the requirements of EN54-17: 2005 and EN54-18: 2005 when used in conjunction with each other. When used singularly, the products will be deemed not to comply with the aforementioned Harmonized standard. | | |

10. Empowered Signatory of Company

Name: Daniel Foster

Position: Head of Science

Signature: 

Date: 16 March 2021